



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

October 10, 2024

Thomas Curtis
Westhill CSD
400 Walberta Rd
Syracuse, NY 13219

RE: Project: CHERRY RD
Pace Project No.: 70316241

Dear Thomas Curtis:

Enclosed are the analytical results for sample(s) received by the laboratory on September 20, 2024. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Latoya Sobratie
latoya.sobratie@pacelabs.com
516-370-6020
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC

575 Broad Hollow Road

Melville, NY 11747

516-370-6000

CERTIFICATIONS

Project: CHERRY RD

Pace Project No.: 70316241

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: KITCHEN 3BAY SINK Lab ID: 70316241001 Collected: 06/28/24 07:30 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8
 Pace Analytical Services - Melville

Lead	6.2	ug/L	1.0	1		10/08/24 09:42	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: KITCHEN HAND SINK								
Lab ID: 70316241002								
Collected: 06/28/24 07:31 Received: 09/20/24 07:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	4.3	ug/L	1.0	1		10/08/24 09:48	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.1	ug/L	1.0	1		10/08/24 09:53	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: **GIRLS ALL GARDEN REST ROOM** Lab ID: 70316241004 Collected: 06/28/24 07:33 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 09:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: **BOY ALL GARDEN REST ROOM** Lab ID: **70316241005** Collected: 06/28/24 07:34 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	2.8	ug/L	1.0	1		10/08/24 09:59	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: **BOY ALL GARDEN REST ROOM** Lab ID: 70316241006 Collected: 06/28/24 07:35 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.1	ug/L	1.0	1		10/08/24 10:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: REST ROOM OFFICE		Lab ID: 70316241007	Collected: 06/28/24 07:36	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: PRINCH PLUS SINK	Lab ID: 70316241008	Collected: 06/28/24 07:37	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 10:04	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: NURSE OFFICE SINK 1 Lab ID: 70316241009 Collected: 06/28/24 07:38 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	5.1	ug/L	1.0	1		10/08/24 10:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: NURSE OFFICE SINK 2		Lab ID: 70316241010	Collected: 06/28/24 07:39	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:07	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: NURSE OFFICE SINK 3 Lab ID: 70316241011 Collected: 06/28/24 07:40 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:09	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: STAFF ROOM SINK		Lab ID: 70316241012	Collected: 06/28/24 07:41	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:10	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: STAFF ROOM MAN SINK		Lab ID: 70316241013	Collected: 06/28/24 07:42	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	75.2	ug/L	1.0	1		10/08/24 10:12	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: STAFF ROOM WOMEN SINK Lab ID: 70316241014 Collected: 06/28/24 07:43 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 110 SINK	Lab ID: 70316241015	Collected: 06/28/24 07:44	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	2.8	ug/L	1.0	1		10/08/24 10:18	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: OUTSIDE 109 SINK	Lab ID: 70316241016	Collected: 06/28/24 07:45	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:20	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 109 SINK		Lab ID: 70316241017	Collected: 06/28/24 07:46	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:22	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 112 BATHROOM SINK		Lab ID: 70316241018	Collected: 06/28/24 07:47	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water
 Analytical Method: EPA 200.8
 Pace Analytical Services - Melville

Lead	<1.0	ug/L	1.0	1		10/08/24 10:23	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 112 CLASSROOM SINK Lab ID: 70316241019 Collected: 06/28/24 07:48 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:25	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 111 REST RM SINK Lab ID: 70316241020 Collected: 06/28/24 07:49 Received: 09/20/24 07:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 10:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 111 CLASS RM SINK		Lab ID: 70316241021	Collected: 06/28/24 07:50	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 114 CLASS RM SINK Lab ID: 70316241022 Collected: 06/28/24 07:51 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8
Pace Analytical Services - Melville

Lead	1.8	ug/L	1.0	1		10/08/24 10:39	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 114 REST RM SINK	Lab ID: 70316241023	Collected: 06/28/24 07:52	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:44	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 113 CLASS RM SINK		Lab ID: 70316241024	Collected: 06/28/24 07:53	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 113 REST RM SINK		Lab ID: 70316241025	Collected: 06/28/24 07:54	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:47	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 116 REST RM SINK								
Lab ID: 70316241026 Collected: 06/28/24 07:55 Received: 09/20/24 07:00 Matrix: Drinking Water								
Analytical Method: EPA 200.8								
Pace Analytical Services - Melville								
200.8 MET ICPMS Drinking Water								
Lead	<1.0	ug/L	1.0	1		10/08/24 10:49	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 116 CLASS RM SINK	Lab ID: 70316241027	Collected: 06/28/24 07:56	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:50	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 115 REST RM SINK		Lab ID: 70316241028	Collected: 06/28/24 07:57	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 10:55	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 115 CLASS RM SINK Lab ID: 70316241029 Collected: 06/28/24 08:00 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.1	ug/L	1.0	1		10/08/24 10:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: **OUTSIDE 211 REST RM SINK** Lab ID: **70316241030** Collected: 06/28/24 08:01 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 10:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 212 REST RM SINK								
Lab ID: 70316241031 Collected: 06/28/24 08:02 Received: 09/20/24 07:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	5.9	ug/L	1.0	1		10/08/24 11:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 213 CLASS RM SINK	Lab ID: 70316241032	Collected: 06/28/24 08:03	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	3.6	ug/L	1.0	1		10/08/24 11:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 214 CLASS RM SINK Lab ID: 70316241033 Collected: 06/28/24 08:04 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.9	ug/L	1.0	1		10/08/24 11:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: HALL FOARLAIN Lab ID: 70316241034 Collected: 06/28/24 08:05 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 11:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 215 CLASS RM SINK		Lab ID: 70316241035	Collected: 06/28/24 08:06	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.4	ug/L	1.0	1		10/08/24 11:06	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 216 CLASS RM SINK		Lab ID: 70316241036	Collected: 06/28/24 08:07	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	4.6	ug/L	1.0	1		10/08/24 11:08	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 218 CLASS RM SINK	Lab ID: 70316241037	Collected: 06/28/24 08:08	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	2.7	ug/L	1.0	1		10/08/24 11:09	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 217 CLASS RM SINK Lab ID: 70316241038 Collected: 06/28/24 08:09 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.9	ug/L	1.0	1		10/08/24 11:14	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 209 SINK		Lab ID: 70316241039	Collected: 06/28/24 08:10	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	2.0	ug/L	1.0	1		10/08/24 11:16	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: REST RM OUTSIDE 209	Lab ID: 70316241040	Collected: 06/28/24 08:12	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 11:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: GIRLS NEAR RM 210	Lab ID: 70316241041	Collected: 06/28/24 08:13	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 11:22	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 208 LEFT SINK 1	Lab ID: 70316241042	Collected: 06/28/24 08:20	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 11:27	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 208 LEFT SINK 2 Lab ID: 70316241043 Collected: 06/28/24 08:21 Received: 09/20/24 07:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 11:35	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 208 RIGHT SINK 1	Lab ID: 70316241044	Collected: 06/28/24 08:22	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 11:36	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 208 RIGHT SINK 2	Lab ID: 70316241045	Collected: 06/28/24 08:23	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 11:38	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: BOY RM BY 203 SINK 1		Lab ID: 70316241046	Collected: 06/28/24 08:24	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	1.8	ug/L	1.0	1		10/08/24 11:40	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: **BOY RM BY 203 SINK 2** Lab ID: **70316241047** Collected: 06/28/24 08:25 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	4.3	ug/L	1.0	1		10/08/24 11:41	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 200 SINK		Lab ID: 70316241048	Collected: 06/28/24 08:26	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 11:43	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 220 SINK	Lab ID: 70316241049	Collected: 06/28/24 08:27	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water

Analytical Method: EPA 200.8
Pace Analytical Services - Melville

Lead

<1.0

ug/L

1.0

1

10/08/24 11:44 7439-92-1

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 220 FAUNTAIN	Lab ID: 70316241050	Collected: 06/28/24 08:28	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.4	ug/L	1.0	1		10/08/24 11:46	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 222 SINK	Lab ID: 70316241051	Collected: 06/28/24 08:29	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 11:48	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 222 FAUNTAIN Lab ID: 70316241052 Collected: 06/28/24 08:30 Received: 09/20/24 07:00 Matrix: Drinking Water								
200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	13.9	ug/L	1.0	1		10/08/24 11:52	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
Sample: RM 224 SINK		Lab ID: 70316241053	Collected: 06/28/24 08:31	Received: 09/20/24 07:00	Matrix: Drinking Water			
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	8.9	ug/L	1.0	1		10/08/24 11:54	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 224 FAUNTAIN		Lab ID: 70316241054	Collected: 06/28/24 08:32	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville			-				
Lead	19.4	ug/L	1.0	1		10/08/24 11:56	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 226 SINK	Lab ID: 70316241055	Collected: 06/28/24 08:33	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 11:57	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 226 FAUNTAIN	Lab ID: 70316241056	Collected: 06/28/24 08:40	Received: 09/20/24 07:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 11:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 118 SINK	Lab ID: 70316241057	Collected: 06/28/24 08:41	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		10/08/24 12:00	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD

Pace Project No.: 70316241

Sample: RM 120 SINK		Lab ID: 70316241058	Collected: 06/28/24 08:42	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	13.1	ug/L	1.0	1		10/08/24 12:02	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 120 FAUNTAIN		Lab ID: 70316241059	Collected: 06/28/24 08:43	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 12:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 122 SINK		Lab ID: 70316241060	Collected: 06/28/24 08:44	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	3.8	ug/L	1.0	1		10/08/24 12:05	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 122 FAUNTAIN		Lab ID: 70316241061	Collected: 06/28/24 08:49	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	9.1	ug/L	1.0	1		10/08/24 12:13	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
Pace Project No.: 70316241

Sample: RM 124 SINK	Lab ID: 70316241062	Collected: 06/28/24 08:46	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	1.6	ug/L	1.0	1		10/08/24 12:18	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Pace Analytical Services, LLC
 575 Broad Hollow Road
 Melville, NY 11747
 516-370-6000

ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: RM 124 FAUNTAIN	Lab ID: 70316241063	Collected: 06/28/24 08:47	Received: 09/20/24 07:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual

200.8 MET ICPMS Drinking Water

Analytical Method: EPA 200.8
 Pace Analytical Services - Melville

Lead	4.4	ug/L	1.0	1		10/08/24 12:23	7439-92-1	
------	-----	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: FAUNTAIN HIGH/BY 121 Lab ID: 70316241064 Collected: 06/28/24 08:48 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
------------	---------	-------	--------------	----	----------	----------	---------	------

200.8 MET ICPMS Drinking Water Analytical Method: EPA 200.8
 Pace Analytical Services - Melville

Lead	<1.0	ug/L	1.0	1		10/08/24 12:24	7439-92-1	
------	------	------	-----	---	--	----------------	-----------	--

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: FAUNTAIN LOW/E		Lab ID: 70316241065	Collected: 06/28/24 08:49	Received: 09/20/24 07:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		10/08/24 12:26	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD
 Pace Project No.: 70316241

Sample: WALL FAUNTAIN BY MUSIC RM Lab ID: 70316241066 Collected: 06/28/24 08:50 Received: 09/20/24 07:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water								
Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		10/08/24 12:31	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CHERRY RD
 Pace Project No.: 70316241

QC Batch: 365777 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70316241001, 70316241002, 70316241003, 70316241004, 70316241005, 70316241006, 70316241007, 70316241008, 70316241009, 70316241010, 70316241011, 70316241012, 70316241013, 70316241014, 70316241015, 70316241016, 70316241017, 70316241018, 70316241019, 70316241020

METHOD BLANK: 1907467 Matrix: Water
 Associated Lab Samples: 70316241001, 70316241002, 70316241003, 70316241004, 70316241005, 70316241006, 70316241007, 70316241008, 70316241009, 70316241010, 70316241011, 70316241012, 70316241013, 70316241014, 70316241015, 70316241016, 70316241017, 70316241018, 70316241019, 70316241020

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/08/24 09:39	

LABORATORY CONTROL SAMPLE: 1907468

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	49.5	99	85-115	

MATRIX SPIKE SAMPLE: 1907471

Parameter	Units	70316241001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	6.2	50	53.3	94	70-130	

MATRIX SPIKE SAMPLE: 1907473

Parameter	Units	70316241002 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	4.3	50	41.8	75	70-130	

SAMPLE DUPLICATE: 1907470

Parameter	Units	70316241001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	6.2	6.1	1	

SAMPLE DUPLICATE: 1907472

Parameter	Units	70316241002 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	4.3	4.3	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CHERRY RD
 Pace Project No.: 70316241

QC Batch: 365778 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Laboratory: Pace Analytical Services - Melville
 Associated Lab Samples: 70316241021, 70316241022, 70316241023, 70316241024, 70316241025, 70316241026, 70316241027,
 70316241028, 70316241029, 70316241030, 70316241031, 70316241032, 70316241033, 70316241034,
 70316241035, 70316241036, 70316241037, 70316241038, 70316241039, 70316241040

METHOD BLANK: 1907474 Matrix: Water
 Associated Lab Samples: 70316241021, 70316241022, 70316241023, 70316241024, 70316241025, 70316241026, 70316241027,
 70316241028, 70316241029, 70316241030, 70316241031, 70316241032, 70316241033, 70316241034,
 70316241035, 70316241036, 70316241037, 70316241038, 70316241039, 70316241040

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/08/24 10:28	

LABORATORY CONTROL SAMPLE: 1907475

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.3	97	85-115	

MATRIX SPIKE SAMPLE: 1907477

Parameter	Units	70316241021 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.9	94	70-130	

MATRIX SPIKE SAMPLE: 1907479

Parameter	Units	70316241022 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	1.8	50	38.8	74	70-130	

SAMPLE DUPLICATE: 1907476

Parameter	Units	70316241021 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1907478

Parameter	Units	70316241022 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	1.8	1.8	1	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CHERRY RD

Pace Project No.: 70316241

QC Batch:	365779	Analysis Method:	EPA 200.8
QC Batch Method:	EPA 200.8	Analysis Description:	200.8 MET No Prep Drinking Water
		Laboratory:	Pace Analytical Services - Melville
Associated Lab Samples:	70316241041, 70316241042, 70316241043, 70316241044, 70316241045, 70316241046, 70316241047, 70316241048, 70316241049, 70316241050, 70316241051, 70316241052, 70316241053, 70316241054, 70316241055, 70316241056, 70316241057, 70316241058, 70316241059, 70316241060		

METHOD BLANK:	1907480	Matrix:	Water
Associated Lab Samples:	70316241041, 70316241042, 70316241043, 70316241044, 70316241045, 70316241046, 70316241047, 70316241048, 70316241049, 70316241050, 70316241051, 70316241052, 70316241053, 70316241054, 70316241055, 70316241056, 70316241057, 70316241058, 70316241059, 70316241060		

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/08/24 11:19	

LABORATORY CONTROL SAMPLE:	1907481					
Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	47.9	96	85-115	

MATRIX SPIKE SAMPLE:	1907483						
Parameter	Units	70316241041 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	47.2	94	70-130	

MATRIX SPIKE SAMPLE:	1907485						
Parameter	Units	70316241042 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	36.8	73	70-130	

SAMPLE DUPLICATE:	1907482					
Parameter	Units	70316241041 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

SAMPLE DUPLICATE:	1907484					
Parameter	Units	70316241042 Result	Dup Result	RPD	Qualifiers	
Lead	ug/L	<1.0	<1.0			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full, without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CHERRY RD
 Pace Project No.: 70316241

QC Batch: 365780 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Laboratory: Pace Analytical Services - Melville
 Associated Lab Samples: 70316241061, 70316241062, 70316241063, 70316241064, 70316241065, 70316241066

METHOD BLANK: 1907486 Matrix: Water
 Associated Lab Samples: 70316241061, 70316241062, 70316241063, 70316241064, 70316241065, 70316241066

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	10/08/24 12:07	

LABORATORY CONTROL SAMPLE: 1907487

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.2	96	85-115	

MATRIX SPIKE SAMPLE: 1907489

Parameter	Units	70316241061 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		9.1	50	56.2	94	70-130

MATRIX SPIKE SAMPLE: 1907491

Parameter	Units	70316241062 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L		1.6	50	50.9	99	70-130

SAMPLE DUPLICATE: 1907488

Parameter	Units	70316241061 Result	Dup Result	RPD	Qualifiers
Lead	ug/L		9.1	9.0	1

SAMPLE DUPLICATE: 1907490

Parameter	Units	70316241062 Result	Dup Result	RPD	Qualifiers
Lead	ug/L		1.6	1.6	0

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: CHERRY RD

Pace Project No.: 70316241

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CHERRY RD
 Pace Project No.: 70316241

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70316241001	KITCHEN 3BAY SINK	EPA 200.8	365777		
70316241002	KITCHEN HAND SINK	EPA 200.8	365777		
70316241003	KITCHEN REST ROOM	EPA 200.8	365777		
70316241004	GIRLS ALL GARDEN REST ROOM	EPA 200.8	365777		
70316241005	BOY ALL GARDEN REST ROOM	EPA 200.8	365777		
70316241006	BOY ALL GARDEN REST ROOM	EPA 200.8	365777		
70316241007	REST ROOM OFFICE	EPA 200.8	365777		
70316241008	PRINCH PLUS SINK	EPA 200.8	365777		
70316241009	NURSE OFFICE SINK 1	EPA 200.8	365777		
70316241010	NURSE OFFICE SINK 2	EPA 200.8	365777		
70316241011	NURSE OFFICE SINK 3	EPA 200.8	365777		
70316241012	STAFF ROOM SINK	EPA 200.8	365777		
70316241013	STAFF ROOM MAN SINK	EPA 200.8	365777		
70316241014	STAFF ROOM WOMEN SINK	EPA 200.8	365777		
70316241015	RM 110 SINK	EPA 200.8	365777		
70316241016	OUTSIDE 109 SINK	EPA 200.8	365777		
70316241017	RM 109 SINK	EPA 200.8	365777		
70316241018	RM 112 BATHROOM SINK	EPA 200.8	365777		
70316241019	RM 112 CLASSROOM SINK	EPA 200.8	365777		
70316241020	RM 111 REST RM SINK	EPA 200.8	365777		
70316241021	RM 111 CLASS RM SINK	EPA 200.8	365778		
70316241022	RM 114 CLASS RM SINK	EPA 200.8	365778		
70316241023	RM 114 REST RM SINK	EPA 200.8	365778		
70316241024	RM 113 CLASS RM SINK	EPA 200.8	365778		
70316241025	RM 113 REST RM SINK	EPA 200.8	365778		
70316241026	RM 116 REST RM SINK	EPA 200.8	365778		
70316241027	RM 116 CLASS RM SINK	EPA 200.8	365778		
70316241028	RM 115 REST RM SINK	EPA 200.8	365778		
70316241029	RM 115 CLASS RM SINK	EPA 200.8	365778		
70316241030	OUTSIDE 211 REST RM SINK	EPA 200.8	365778		
70316241031	RM 212 REST RM SINK	EPA 200.8	365778		
70316241032	RM 213 CLASS RM SINK	EPA 200.8	365778		
70316241033	RM 214 CLASS RM SINK	EPA 200.8	365778		
70316241034	HALL FOARLAIN	EPA 200.8	365778		
70316241035	RM 215 CLASS RM SINK	EPA 200.8	365778		
70316241036	RM 216 CLASS RM SINK	EPA 200.8	365778		
70316241037	RM 218 CLASS RM SINK	EPA 200.8	365778		
70316241038	RM 217 CLASS RM SINK	EPA 200.8	365778		
70316241039	RM 209 SINK	EPA 200.8	365778		
70316241040	REST RM OUTSIDE 209	EPA 200.8	365778		
70316241041	GIRLS NEAR RM 210	EPA 200.8	365779		
70316241042	RM 208 LEFT SINK 1	EPA 200.8	365779		
70316241043	RM 208 LEFT SINK 2	EPA 200.8	365779		
70316241044	RM 208 RIGHT SINK 1	EPA 200.8	365779		
70316241045	RM 208 RIGHT SINK 2	EPA 200.8	365779		
70316241046	BOY RM BY 203 SINK 1	EPA 200.8	365779		
70316241047	BOY RM BY 203 SINK 2	EPA 200.8	365779		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CHERRY RD
Pace Project No.: 70316241

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70316241048	RM 200 SINK	EPA 200.8	365779		
70316241049	RM 220 SINK	EPA 200.8	365779		
70316241050	RM 220 FAUNTAIN	EPA 200.8	365779		
70316241051	RM 222 SINK	EPA 200.8	365779		
70316241052	RM 222 FAUNTAIN	EPA 200.8	365779		
70316241053	RM 224 SINK	EPA 200.8	365779		
70316241054	RM 224 FAUNTAIN	EPA 200.8	365779		
70316241055	RM 226 SINK	EPA 200.8	365779		
70316241056	RM 226 FAUNTAIN	EPA 200.8	365779		
70316241057	RM 118 SINK	EPA 200.8	365779		
70316241058	RM 120 SINK	EPA 200.8	365779		
70316241059	RM 120 FAUNTAIN	EPA 200.8	365779		
70316241060	RM 122 SINK	EPA 200.8	365779		
70316241061	RM 122 FAUNTAIN	EPA 200.8	365780		
70316241062	RM 124 SINK	EPA 200.8	365780		
70316241063	RM 124 FAUNTAIN	EPA 200.8	365780		
70316241064	FAUNTAIN HIGH/BY 121	EPA 200.8	365780		
70316241065	FAUNTAIN LOW/E	EPA 200.8	365780		
70316241066	WALL FAUNTAIN BY MUSIC RM	EPA 200.8	365780		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104


Chain of Custody Record

WO#: 70316241

7809

Client: Westhill CSD Phone # 315-426-3396
 Address: 400 West Genesee Rd Fax # _____
Syracuse NY 13219

Contact Person: LSL P
 Client's Site I.D.: Cherry Rd
 Client's Project I.D.:



Authorization:

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
1	Kitchen 3 Bay sink	6-28-2009	730	X		PW	None	1	250 mL	Lead	Sent to Peer	
2	Kitchen Hand Sink		731	X				1				
3	Kitchen Rest Room		732	X				1				
4	Girls All Gender Rest Room		733	X				1				
5	Boys All Gender Rest Room		734	X				1				
6	Boys' Rest Room		735	X				1				
7	Rest Room Principal office		736	X				1				
8	Principal's Sink		737	X				1				
9	Nurse office Sink 1		738	X				1				
10	Nurse office Sink 2		739	X				1				
11	Nurse office Sink 3		740	X				1				
12	Staff Room Sink		741	X				1				
13	Staff Room Men's Sink		742	X				1				
14	Staff Room Women's Sink		743	X				1				

Notes and Hazard identifications:
 231C
 Samples Preserved Upon Receipt at Lab
 to PHCZ

Custody Transfers		Date	Time
Sampled and Relinquished By: Print Name: <u>Thomas Cunti</u>	Signature: <u>[Signature]</u>	6/28/2009	1000
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>Judith [Signature]</u>	6/28/2009	1008
Shipment Method: <u>Insured</u>	Samples Received Intact: <u>Y</u>		

Be - Haz 9/20/29

San SC 9/14/24/1910

PLM D.LI 9/20/29

Page 76 of 81



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record

7809

Client: West Hill CSD Phone # 315-426-3396

Address: 400 Walburns Rd Fax # _____
Syracuse NY 13219

Authorization: _____

Contact Person: _____ LSL Project #: _____

Client's Site I.D.: Cherry Rd

Client's Project I.D.: _____

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
⑤ Rm 110	SLNK	6-25-04	744	X		PW	None	1	250 mL	Lead		Sent to POC
⑫ Outside 109	SLNK		745	X				1				
17 Rm 109	SLNK		746	X				1				
18 Rm 112	Bath room sink		747	X				1				
19 Rm 112	Class room sink		748	X				1				
20 Rm 111	Rest Rm sink		749	X				1				
21 Rm 111	Class Rm sink		750	X				1				
22 Rm 114	Class Rm sink		751	X				1				
23 Rm 114	Rest Rm sink		752	X				1				
24 Rm 113	Class Rm sink		753	X				1				
25 Rm 113	Rest Rm sink		754	X				1				
26 Rm 116	Rest Rm sink		755	X				1				
27 Rm 116	Class Rm sink		756	X				1				
28 Rm 115	Rest Rm sink		757	X				1				
29 Rm 115												

Notes and Hazard Identifications: 23.1K

Samples Preserved Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By: Print Name: <u>Thomas Cuckey</u> Signature: <u>[Signature]</u>		<u>6/25/04</u>	<u>10:00</u>
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>[Signature]</u>	<u>6/28/04</u>	<u>10:08</u>
Shipment Method: <u>Judy Rizzo 911/24</u> Samples received intact: <u>Y N</u>			




Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record



7809

Client: Westhill CSD Phone # _____
 Address: 400 Walburn Rd Fax # _____
Syracuse NY 13219

Contact Person: _____ LSL Project #: _____
 Client's Site I.D.: Cherry Rd
 Client's Project I.D.: _____

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
29	Rm 115 class Rm sink	6-25-24	800	X		PW	None	1	250 ml	Lead Sent to Puce		
30	outside 24 Rest Rm sink		801	X				1				
31	Rm 212 Rest Rm sink		802	X				1				
32	Rm 213 class Rm sink		803	X				1				
33	Rm 214 class Rm sink		804	X				1				
34	hall fountain		805	X				1				
35	Rm 215 class Rm sink		806	X				1				
36	Rm 216 class Rm sink		807	X				1				
37	Rm 218 class Rm sink		808	X				1				
38	Rm 217 class Rm sink		809	X				1				
39	Rm 209 sink		810	X				1				
40	Rest Rm outside 209		811	X				1				
40	Rest Rm outside 209		812	X				1				
42	girls near Rm 210		813	X				1				

Notes and Hazard identifications:
 Samples Preserved 23.1c
 Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By: Print Name: <u>Thomas Cook</u>	Signature: <u>[Signature]</u>	<u>6/28/24</u>	<u>1:00</u>
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>[Signature]</u>	<u>6/28/24</u>	<u>10:08</u>
Shipment Method: <u>[Signature]</u>	Samples Received Intact: <u>Y</u> <u>N</u>		



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057

Phone # (315) 445-1900

Telefax # (315) 445-1104

Chain of Custody Record



7809

Client: Westhill CSD Phone # _____
 Address: 400 Walburne Rd Fax # _____
Syracuse NY 130219

Contact Person: _____ LSL Project #: _____
 Client's Site I.D.: Cherry Rd
 Client's Project I.D.: _____

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
42	Rm 208 Left sink 1	6/28/24	820	X		PW	None	1	250 mL	Lead Sent to Price		
43	Rm 208 Left sink 2		821	X				1				
44	Rm 208 Right sink 1		822	X				1				
45	Rm 208 Right sink 2		822	X				1				
46	Boy Rm By 203 sink 1		824	X				1				
47	Boy Rm By 203 sink 2		825	X				1				
48	Rm 200 Sink		824	X				1				
49	Rm 220 Sink		827	X				1				
50	Rm 220 Bathroom		828	X				1				
51	Rm 222 Sink		829	X				1				
52	Rm 222 Bathroom		830	X				1				
53	Rm 224 Sink		831	X				1				
54	Rm 224 Bathroom		832	X				1				
55	Rm 224 Sink		833	X				1				

Notes and Hazard identifications:
 Samples Preserved 23°C
 Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By: Print Name: <u>Thomas Curtis</u>	Signature: <u>[Signature]</u>	<u>6/28/24</u>	<u>1000</u>
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>[Signature]</u>	<u>6/28/2024</u>	<u>1008</u>
Shipment Method: <u>[Signature]</u>	Samples Received Intact: <u>Y</u>		



Life Science Laboratories, Inc.

5854 Butternut Drive
East Syracuse, NY 13057
Phone # (315) 445-1900

Chain of Custody Record

Telefax # (315) 445-1104

Contact Person:

LSL Project #:



5

7809

Client: Westhill CSP Phone # _____
 Address: 400 Walburn Rd Fax # _____
Syracuse NY 13219

Authorization: _____

Client's Site I.D.: Cherry Rd

Client's Project I.D.: _____

LSL Sample Number	Client's Sample Identifications	Sample Date	Sample Time	Type		Matrix	Preserv. Added	Containers		Analyses	Free Cl (mg/L)	Pres. Check
				grab	comp.			#	size/type			
56 Rm 226	fontain	6/28/24	846	X		PW	None	1	250 mL	Lead Sent to Pace		
57 Rm 118	SINK		841	X				1				
58 Rm 120	SINK		842	X				1				
59 Rm 120	fontain		843	X				1				
60 Rm 122	SINK		844	X				1				
61 Rm 122	fontain		845	X				1				
62 Rm 124	SINK		846	X				1				
63 Rm 124	fontain		847	X				1				
64 fontain	High/BY/21		848	X				1				
65 fontain	Low/E		849	X				1				
66 Wake fontain	By Music Rm		850	X				1				
67				X				1				
68				X				1				
69				X				1				

Notes and Hazard identifications:

Samples Preserved
Upon Receipt at Lab

Custody Transfers		Date	Time
Sampled and Relinquished By:	Print Name: <u>Thomas Cuts</u>	Signature: <u>[Signature]</u>	6/28/24 10:00
Received By:			
Relinquished By:	Received By:		
Relinquished By:	Received for Lab By: <u>[Signature]</u>	6/28/24 10:08	
Shipment Method: <u>[Signature]</u>	9/19/24	Samples Received Intact: Y N	

WO#: 70316241

Client Name: WESTHILLCSD

Project #: PM: LS2 Due Date: 10/04/24

Courier: Fed Ex UPS USPS Client Commercial Parcel Other

CLIENT: WESTHILLCSD

Tracking #:

Custody Seal on Cooler/Box Present: Yes No Seals Intact: Yes No Temperature Blank Present: Yes No
Packing Material: Bubble Wrap Bubble Bags Ziploc None Other Type of Ice: Wet Blue None

Thermometer Used: T+211 Correction Factor: +0.3 Samples on ice, cooling process has begun
Cooler Temperature (°C): 4.8 Cooler Temperature Corrected (°C): 5.1 Date/Time 5035A kits placed in freezer _____
Temp should be above freezing to 5.0°C

USDA Regulated Soil (N/A, water sample)

Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No

Did samples originate from a foreign source including Hawaii and Puerto Rico)? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.

Date and Initials of person examining contents: 10/4/24 ABP

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2.
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3.
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Face Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix: SL <input checked="" type="checkbox"/> WT <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation: 10/4/24 ABP

All containers needing preservation have been pH paper Lot # <u>213624</u> All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, NaOH > 12 Cyanide) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	13. <input type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl Sample # Initial when completed: _____ Lot # of added preservative: _____ Date/Time preservative added: _____
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A KI starch test strips Lot #	14. Positive for Res. Chlorine? Y N
Residual chlorine strips Lot #	
SM 4500 CN samples checked for sulf <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Lead Acetate Strips Lot #	15. Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	
Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.
Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	

Client Notification/ Resolution:

Field Data Required? Y / N

Person Contacted:

Date/Time:

Comments/ Resolution:

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS



February 06, 2025

Thomas Curtis
Westhill CSD
400 Walberta Rd
Syracuse, NY 13219

RE: Project: CRS RETEST
Pace Project No.: 70335444

Dear Thomas Curtis:

Enclosed are the analytical results for sample(s) received by the laboratory on January 30, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:
• Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Latoya Sobratie
latoya.sobratie@pacelabs.com
516-370-6020
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: CRS RETEST
Pace Project No.: 70335444

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747

Connecticut Certification #: PH-0435

Delaware Certification # NY 10478

Maryland Certification #: 208

Massachusetts Certification #: M-NY026

New Hampshire Certification #: 2987

New Jersey Certification #: NY158

New York Certification #: 10478 Primary Accrediting Body

Pennsylvania Certification #: 68-00350

Rhode Island Certification #: LAO00340

Texas Certification #: T104704582

Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CRS RETEST
 Pace Project No.: 70335444

Sample: **CRS KITCHEN SUPPLY LINE** Lab ID: **70335444001** Collected: 01/29/25 13:00 Received: 01/30/25 06:00 Matrix: Drinking Water

Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		02/04/25 15:17	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CRS RETEST
 Pace Project No.: 70335444

QC Batch: 383057 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Laboratory: Pace Analytical Services - Melville

Associated Lab Samples: 70335444001

METHOD BLANK: 2010975 Matrix: Water
 Associated Lab Samples: 70335444001

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	02/04/25 14:41	

LABORATORY CONTROL SAMPLE: 2010976

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	48.6	97	85-115	

MATRIX SPIKE SAMPLE: 2010978

Parameter	Units	70335402030 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	51.7	103	70-130	

MATRIX SPIKE SAMPLE: 2010980

Parameter	Units	70335402031 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	50.0	100	70-130	

SAMPLE DUPLICATE: 2010977

Parameter	Units	70335402030 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 2010979

Parameter	Units	70335402031 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: CRS RETEST
Pace Project No.: 70335444

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.




QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CRS RETEST
Pace Project No.: 70335444

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70335444001	CRS KITCHEN SUPPLY LINE	EPA 200.8	383057		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Client Name: West Hill CSD Project # _____
 Courier: Fed Ex UPS USPS Client Commercial Parcel Other _____
 Tracking #: _____

Custody Seal on Cooler/Box Present: Yes No Seals intact: Yes No Temperature Blank Present: Yes No
 Packing Material: Bubble Wrap Bubble Bags Ziplo None Other Type of Ice: Wet Blue None
 Thermometer Used: TH211 Correction Factor: 40.0 Samples on ice, cooling process has begun
 Cooler Temperature (°C): 0.8 Cooler Temperature Corrected (°C): 0.8 Date/Time 5035A kits placed in freezer _____
 Temp should be above freezing to 6.0°C

USDA Regulated Soil (N/A, water sample)
 Did samples originate in a quarantine zone within the United States: AL, AR, CA, FL, GA, ID, LA, MS, NC, NM, NY, OK, OR, SC, TN, TX, or VA (check map)? Yes No
 Did samples originate from a foreign source including Hawaii and Puerto Rico? Yes No

If Yes to either question, fill out a Regulated Soil Checklist (ENV-FRM-MELV-0076) and include with SCUR/COC paperwork.
 Date and Initials of person examining contents: ABB 1/30/25

	COMMENTS:
Chain of Custody Present: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1.
Chain of Custody Filled Out: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	2. collect time missing on COC
Chain of Custody Relinquished: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	3. time filled from bottle 13:00
Sampler Name & Signature on COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	4.
Samples Arrived within Hold Time: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	5.
Short Hold Time Analysis (<72hr): <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6.
Rush Turn Around Time Requested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	7.
Sufficient Volume: (Triple volume provided for MS/MSD) <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	8.
Correct Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	9.
-Pace Containers Used: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Containers Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	10.
Filtered volume received for Dissolved tests <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	11. Note: if sediment is visible in the dissolved container.
Sample Labels match COC: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	12.
-Includes date/time/ID/Analysis Matrix <input checked="" type="checkbox"/> SL <input type="checkbox"/> W <input type="checkbox"/> OIL <input type="checkbox"/> OTHER	

Date and Initials of person checking preservation: ABB 1/30/25

All containers needing preservation have been pH paper Lot # <u>231224</u> <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A	13. <input checked="" type="checkbox"/> HNO ₃ <input type="checkbox"/> H ₂ SO ₄ <input type="checkbox"/> NaOH <input type="checkbox"/> HCl
All containers needing preservation are found to be in compliance with method recommendation? (HNO ₃ , H ₂ SO ₄ , HCl, NaOH > 9 Sulfide, <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> N/A (NaOH > 12 Cyanide) Exceptions: VOA, Coliform, TOC/DOC, Oil and Grease, DRO/8015 (water). Per Method, VOA pH is checked after analysis	Sample # _____ Initial when completed: <u>ABB</u> Lot # of added preservative: <u>1121089</u> Date/Time preservative added: <u>1/30/25 14:44</u>
Samples checked for dechlorination: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A KI starch test strips Lot # _____ Residual chlorine strips Lot # _____	14. Positive for Res. Chlorine? Y N
SM 4500 CN samples checked for sul <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Lead Acetate Strips Lot # _____	15. Positive for Sulfide? Y N
Headspace in ALK Bottle (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Headspace in VOA Vials (>6mm): <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	16.
Trip Blank Present: <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A Trip Blank Custody Seals Present <input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> N/A	17.

Client Notification/ Resolution: _____ Field Data Required? Y / N
 Person Contacted: _____ Date/Time: _____
 Comments/ Resolution: _____

* PM (Project Manager) review (which includes the SCUR) is documented electronically in LIMS.



Pace Analytical Services, LLC
575 Broad Hollow Road
Melville, NY 11747
516-370-6000

January 23, 2025

Thomas Curtis
Westhill CSD
400 Walberta Rd
Syracuse, NY 13219

RE: Project: CHERRY RD 1/9
Pace Project No.: 70332190

Dear Thomas Curtis:

Enclosed are the analytical results for sample(s) received by the laboratory on January 10, 2025. The results relate only to the samples included in this report. Results reported herein conform to the applicable TNI/NELAC Standards and the laboratory's Quality Manual, where applicable, unless otherwise noted in the body of the report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Melville

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

Latoya Sobratie
latoya.sobratie@pacelabs.com
516-370-6020
Project Manager

Enclosures



REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: CHERRY RD 1/9
Pace Project No.: 70332190

Pace Analytical Services, LLC - Melville, NY

575 Broad Hollow Rd, Melville, NY 11747
Connecticut Certification #: PH-0435
Delaware Certification # NY 10478
Maryland Certification #: 208
Massachusetts Certification #: M-NY026
New Hampshire Certification #: 2987

New Jersey Certification #: NY158
New York Certification #: 10478 Primary Accrediting Body
Pennsylvania Certification #: 68-00350
Rhode Island Certification #: LAO00340
Texas Certification #: T104704582
Florida Certification #: E871198

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD 1/9

Pace Project No.: 70332190

Sample: #1KITCHEN FEED LINE	Lab ID: 70332190001	Collected: 01/09/25 07:30	Received: 01/10/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	20.5	ug/L	1.0	1		01/17/25 12:58	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD 1/9
Pace Project No.: 70332190

Sample: #2 NEW FOUNTAIN OUT SIDE ROOM	Lab ID: 70332190002	Collected: 01/09/25 07:35	Received: 01/10/25 06:00	Matrix: Drinking Water					
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual	
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville								
Lead	<1.0	ug/L	1.0	1		01/17/25 12:59	7439-92-1		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD 1/9

Pace Project No.: 70332190

Sample: #3 STAFF ROOM	Lab ID: 70332190003	Collected: 01/09/25 07:40	Received: 01/10/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	<1.0	ug/L	1.0	1		01/17/25 13:01	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD 1/9
 Pace Project No.: 70332190

Sample: #4 KITCHEN 3 BAY SINK		Lab ID: 70332190004	Collected: 01/09/25 07:45	Received: 01/10/25 06:00	Matrix: Drinking Water			
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water		Analytical Method: EPA 200.8 Pace Analytical Services - Melville						
Lead	<1.0	ug/L	1.0	1		01/17/25 13:03	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: CHERRY RD 1/9
Pace Project No.: 70332190

Sample: #5 KITCHEN HAND SINK	Lab ID: 70332190005	Collected: 01/09/25 08:00	Received: 01/10/25 06:00	Matrix: Drinking Water				
Parameters	Results	Units	Report Limit	DF	Prepared	Analyzed	CAS No.	Qual
200.8 MET ICPMS Drinking Water	Analytical Method: EPA 200.8 Pace Analytical Services - Melville							
Lead	39.1	ug/L	1.0	1		01/17/25 13:04	7439-92-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: CHERRY RD 1/9
 Pace Project No.: 70332190

QC Batch: 380482 Analysis Method: EPA 200.8
 QC Batch Method: EPA 200.8 Analysis Description: 200.8 MET No Prep Drinking Water
 Laboratory: Pace Analytical Services - Melville
 Associated Lab Samples: 70332190001, 70332190002, 70332190003, 70332190004, 70332190005

METHOD BLANK: 1996790 Matrix: Water
 Associated Lab Samples: 70332190001, 70332190002, 70332190003, 70332190004, 70332190005

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
Lead	ug/L	<1.0	1.0	01/17/25 12:40	

LABORATORY CONTROL SAMPLE: 1996791

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	50	50.8	102	85-115	

MATRIX SPIKE SAMPLE: 1996832

Parameter	Units	70332627001 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	48.4	97	70-130	

MATRIX SPIKE SAMPLE: 1996834

Parameter	Units	70331937004 Result	Spike Conc.	MS Result	MS % Rec	% Rec Limits	Qualifiers
Lead	ug/L	<1.0	50	52.7	105	70-130	

SAMPLE DUPLICATE: 1996831

Parameter	Units	70332627001 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

SAMPLE DUPLICATE: 1996833

Parameter	Units	70331937004 Result	Dup Result	RPD	Qualifiers
Lead	ug/L	<1.0	<1.0		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
 without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: CHERRY RD 1/9
Pace Project No.: 70332190

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

Pace Analytical is TNI accredited. Contact your Pace PM for the current list of accredited analytes.

TNI - The NELAC Institute.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: CHERRY RD 1/9
Pace Project No.: 70332190

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
70332190001	#1 KITCHEN FEED LINE	EPA 200.8	380482		
70332190002	#2 NEW FOUNTAIN OUT SIDE ROOM	EPA 200.8	380482		
70332190003	#3 STAFF ROOM	EPA 200.8	380482		
70332190004	#4 KITCHEN 3 BAY SINK	EPA 200.8	380482		
70332190005	#5 KITCHEN HAND SINK	EPA 200.8	380482		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CHAIN-OF-CUSTODY Analytical Request Document

Cherry Rd Retest

LAB U

WO#: 70332190

Number or MTJL Log-in



70332190

E ONLY

Chain-of-Custody is a LEGAL DOCUMENT- Complete all relevant fields

Company: West Hill Central School
 Address: 400 Walburne Rd Syracuse NY 13219
 Report To: Tom Curtis
 Email To: tcurtis@westhillschools.org

Copy To:
 Customer Project Name/Number: Cherry Rd Retest
 Phone: 315-426-3396
 Email: 315-426-3396
 Collected by (print): Tom Curtis 1-9-2025
 Collected by (signature): [Signature] 1-9-2025
 Sample Disposal: [] Dispose as appropriate [] Return [] Archive [] Hold

* Matrix Codes (Insert in Matrix box below): Drinking Water (DW), Ground Water (GW), Wastewater (WW), Product (P), Soil/Solid (SL), Oil (OL), Wipes (WP), Air (AR), Tissue (TS), Bioassay (B), Vapor (V), Other (OT)

Customer Sample ID	Matrix*	Compl Grab	Collected (or Composite Start)		Composite End		Res Cl	# of Ctns
			Date	Time	Date	Time		
#1 Blueberry Kitchen Red	W		1/9/2025	7:30 AM				
#2 New Mountain outdoor base	W		1/9/2025	7:35 AM				
#3 Staff Room	W		1/9/2025	7:40 AM				
#4 Kitchen 3 Bay sink	W		1/9/2025	7:45 AM				
#5 Kitchen Hand sink	W		1/9/2025	8:00 AM				

Customer Remarks/ Special Conditions/ Possible Hazards:
 Type of Ice Used: Wet [X] Snow [] Dry [] None []
 Packing Material Used: []
 Radchem sample(s) screened: (<800 cpm): [] Y [] N []
 Samples received via: FEDEX [] UPS [] Client [] Courier [] Pace Courier []
 SHORT HOLDS PRESENT (< 72 hours): Y N NA
 MTJL LAB USE ONLY
 Table #: _____
 ACCT #: _____
 Template: _____
 Prelogin: _____
 PM: _____
 PB: _____

Relinquished by Company: (Signature) _____
 Date/Time: 1/9/25 1700
 Relinquished by Company: (Signature) _____
 Date/Time: 1-9-25
 Relinquished by Company: (Signature) _____
 Date/Time: _____

Container Preservative Type**
 Lab Project Manager:
 ** Preservative Types: (1) nitric acid, (2) sulfuric acid, (3) hydrochloric acid, (4) sodium hydroxide, (5) zinc acetate, (6) methanol, (7) sodium bisulfate, (8) sodium bisulfite, (9) hexane, (A) ascorbic acid, (B) ammonium sulfate, (C) ammonium hydroxide, (D) TSP, (U) Unpreserved, (O) Other _____

Analyses

LAB Profile Line:	LAB Sample Receipt Checklist:
	Custody Seals Present/Intact <input checked="" type="checkbox"/> N NA
	Custody Signatures Present <input checked="" type="checkbox"/> N NA
	Collector Signatures Present <input checked="" type="checkbox"/> N NA
	Bottles Intact <input checked="" type="checkbox"/> N NA
	Correct Bottles <input checked="" type="checkbox"/> N NA
	Sufficient Volume <input checked="" type="checkbox"/> N NA
	Samples received on ice <input checked="" type="checkbox"/> N NA
	VOA - Headspace Acceptable <input checked="" type="checkbox"/> Y N NA
	USDA Regulated Soils <input checked="" type="checkbox"/> Y N NA
	Samples in holding time <input checked="" type="checkbox"/> Y N NA
	Residual Chlorine Present <input checked="" type="checkbox"/> Y N NA
	Cl Strips: _____
	Sample pH Acceptable <input checked="" type="checkbox"/> N NA
	pH Strips: 213624
	Sulfide Present <input checked="" type="checkbox"/> Y N NA
	Lead Acetate Strips: _____

LAB USE ONLY:
 Lab Sample # / Comments

LAB Sample Temperature Info:
 Temp Blank received: Y N NA
 Therm ID #: 74711
 Cooler 1 Temp Upon Receipt 0.8 °C
 Cooler 1 Therm Corr. Factor +0.0 °C
 Cooler 1 Corrected Temp 0.8 °C
 Comments:
 Trip Blank Received: Y N NA
 HCL MeOH TSP Other
 Non-Conformance(s) Page _____
 YES / NO of _____

165 1/10 66

- #1 Kitchen Sced trap
- #2 new fountain out side Room 116
- #3 Staff Room 105
- #4 kitchen 3 Bay sink
- #5 Kitchen hand wash sink

Sample Receiving Non-Conformance Form (NCF)

Date: 1/10/25 Evaluated by: _____
 Location: _____

WO#: **70332190**
 PH: LS2 Due Date: 01/24/25
 CLIENT: WESTHILLCSD

If Chain-of-Custody (COC) is not received; contact client and if necessary, fill out a COC and indicate that it was filled out by personnel. Note issues on this NCF.

If COC is incomplete, check applicable issues below and add details where appropriate:

Collection date/time missing or incorrect	<input checked="" type="checkbox"/> Analyses or analytes: missing or clarification needed	Samples listed on COC do not match samples received (missing, additional, etc.)
Sample IDs on COC do not match sample labels	Required trip blanks were not received	Required signatures are missing

Comments/Details/Other Issues not listed above:

Analyses missing on COC

Sample integrity issues: check applicable issues below and add details where appropriate:

Samples: Past holding time	Samples: Condition needs to be brought to lab personnel's attention (details below)	Preservation: Improper
Samples: Not field filtered	Containers: Broken or compromised	Temperature: not within acceptance criteria (typical 0-6C)
Samples: Insufficient volume received	Containers: Incorrect	Temperature: Samples arrived frozen
Samples: Cooler damaged or compromised	Custody Seals: Missing or compromised on samples, trip blanks or coolers	Vials received with improper headspace
Samples: contain chlorine or sulfides	Packing Material: Insufficient/Improper	Other:

Comments/Details:

4. If Samples not preserved properly and Sample Receiving adjusts pH, add details below:

Sample ID: <u>All samples</u>	Date/Time: <u>1/10/25 16:30</u>	Amount/type pres added: <u>3ml HNO₃</u>
Preserved by: <u>ASP</u>	Initial and Final pH: <u>7-7.2</u>	Lot # of pres added: <u>24007769</u>
Sample ID:	Date/Time:	Amount/type pres added:
Preserved by:	Initial and Final pH:	Lot # of pres added:
Sample ID:	Date/Time:	Amount/type pres added:
Preserved by:	Initial and Final pH:	Lot # of pres added:

5. Client Contact: If client is contacted for any issue listed above, fill in details below:

Client: <u>Thomas Curtis</u>	Contacted per:
PM Initials: <u>LS2</u>	Date/Time: <u>1/13/25 14:12 pm</u>

Client Comments/Instructions: