



RICHARD B. CHAPMAN
*Assistant Superintendent for
Curriculum and Instruction*
Phone (315) 426-3272

STEPHEN R. DUNHAM
Superintendent of Schools
400 Walberta Road
Syracuse, New York 13219-2214
Phone (315) 426-3272
Fax (315) 488-6411

STEVEN E. SMITH
*Assistant Superintendent for
Business Administration*
Phone (315) 426-3000

January 24, 2025

Dear Parents, Guardians and Staff:

The Westhill Central School District has received the results for lead testing the water at Walberta Park Elementary School. All potable water outlets that are in service were tested. Twelve outlets came back with levels matching or exceeding the action level, 5 micrograms per liter, 0.005 milligrams per liter (mg/l), or 5 parts per billion. Non potable water signs have been placed next to the non-compliant outlets until remediation and retesting is completed.

Please feel free to contact my office if you have any questions.

Sincerely,
Thomas Curtis
Director of Facilities
Westhill Central School District
201 Cherry Road
Syracuse, NY 13219
(315) 426-3396